

Utah Department of Environmental Quality

Division of Drinking Water

Public Water System Inventory Report

Run Date:
08/04/2011 01:03 pm

PWS ID: UTAH27003 **Name:** DIXIE DEER SSD

Legal Contact: DIXIE DEER SSD **Rating:** Approved
KATHY PAXSON **Rating Date:** 11/10/1986

Address: 316 North Lodge Road **Activity Status:** Active
CENTRAL, UT 84722

Phone Number: 435-574-3337

City Served (Area):

County: WASHINGTON COUNTY

System Type: Community **Last Inv Update:** 03/14/2011 **Avg Daily Prod:**

Activity Status Cd: Active **Last Snty Srv Dt:** 09/16/2009 **Total Dsgn Cap:**

Population: 500 **Surveyor:** MICHAEL S MOSS **Total Emerg Cap:**

Oper Period: 1/1 to 12/31

Gal/Day Gal/Min

Contacts

Contact Type	Name	Title	Phone Numbers		Email Address
			Office	Emergency	
AC	PAXSON, KATHY	MANAGER	702-371-6603	435-574-0592	

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Residential	Metered	0.75	327
			327 Total Svc Connections

Storage

Total Storage: 375,000 GAL **Number of Units:** 2 **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matrl	Overflow Elev	Activity Status	Press'd
ST001	STORAGE FACILITY ST001	Ground	125,000 GAL	Steel	5514	A	NO
ST002	STORAGE FACILITY ST002	Ground	250,000 GAL	Concrete	5514	A	NO

Treatment Plants

No.	Plant Name	Approved Design Capacity (gal/day)	Activity Status	Treatment Process
TP001	DIXIE DEER CHLORINATOR		A	

Distribution System

Pump Type	Total Dyn Head ft H2O P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No				

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	WELL #2	Inactive	WL	8	166 GPM	160 GPM	Yes	GW	Permanent	1/1 to 12/31	
WS002	WELL #4	Active	WL		290 GPM	235 GPM	Yes	GW	Permanent	1/1 to 12/31	

*Reports measured flow for wells, approved design capacity for all other sources.